

**SUBCHAPTER 5. REGISTRATION, EMISSION INVENTORY AND ANNUAL  
OPERATING FEES**

Section

252:100-5-2.3. Periodic stack test required [NEW]

**252:100-5-2.3. Periodic stack test required**

(a) The owner or operator shall conduct periodic stack test(s) on each unit of fuel-burning equipment described below, in accordance with subsection (b) of this section. Each unit shall be tested to determine the emissions of oxides of nitrogen, carbon monoxide and volatile organic compounds. Solid and liquid-fired fuel-burning units shall also be tested to determine emissions of PM-10:

(1) stationary internal combustion engines rated at 600 brake horsepower or more;

(2) stationary turbines rated at 5,000 brake horsepower or more; and

(3) boilers rated at 60,000,000 BTU per hour heat input or more.

(b) Each unit shall be tested at any time within the first 44,000 hours of operation following January 1, 2000, and thereafter before completion of each additional 44,000 hours of operation.

(c) Stack testing shall be conducted in accordance with the requirements of OAC 252:100-5-2.1(d)(2) and (3).

(d) The Director shall waive the stack testing requirements for any pollutant upon the written request of the owner or operator if:

(1) a current permit limits emissions of the pollutant from the fuel-burning equipment; or

(2) the fuel-burning equipment is equipped with an operational emission monitoring system that provides all the data necessary to calculate emissions of the pollutant; or

(3) the owner or operator is required by federal regulation to conduct periodic stack testing of the fuel-burning equipment for the pollutant; or

(4) the owner or operator can provide other data that demonstrates to the satisfaction of the Director that emissions of the pollutant from the fuel-burning equipment are true and accurate as reported.