

**SUBCHAPTER 37. CONTROL OF EMISSION OF VOLATILE ORGANIC  
COMPOUNDS (VOCs)**

Section:

**PART 1. GENERAL PROVISIONS**

- 252:100-37-1. Purpose
- 252:100-37-2. Definitions
- 252:100-37-3. Applicability and compliance
- 252:100-37-4. Exemptions
- 252:100-37-5. Operation and maintenance

**PART 3. CONTROL OF VOCs IN STORAGE AND LOADING OPERATIONS**

- 252:100-37-15. Storage of VOCs
- 252:100-37-16. Loading of VOCs
- 252:100-37-17. Effluent water separators [AMENDED AND  
RENUMBERED TO 252:100-37-37]

- 252:100-37-18. Pumps and compressors [AMENDED AND  
RENUMBERED TO 252:100-37-38]

**PART 5. CONTROL OF VOCs IN COATING OPERATIONS**

- 252:100-37-25. Coating of parts and products
- 252:100-37-26. Clean up with VOCs

**PART 7. CONTROL OF SPECIFIC PROCESSES**

- 252:100-37-35. Waste gas disposal
- 252:100-37-36. Fuel-burning and refuse-burning  
equipment

- 252:100-37-37. Effluent water separators
- 252:100-37-38. Pumps and compressors

**PART 9. PERMIT BY RULE FOR VOC STORAGE AND LOADING**

**FACILITIES [REVOKED]**

- 252:100-37-41. Applicability [REVOKED]
- 252:100-37-42. Permit-by-rule requirements [REVOKED]

**PART 9. PERMIT BY RULE FOR VOC STORAGE AND LOADING  
FACILITIES [REVOKED]**

**252:100-37-41. Applicability [REVOKED]**

~~Any new VOC storage and/or loading facility may be constructed and any existing VOC storage and/or loading facility may be operated under this Part if the following conditions are met.~~

~~— (1) The facility is located in an area designated as unknown or attainment for ozone.~~

~~— (2) Each storage vessel located at the facility meets one of the following criteria.~~

~~— (A) The storage capacity is 19,813 gal (75 m<sup>3</sup>) or less.~~

~~— (B) The storage capacity is greater than 19,813 gal (75 m<sup>3</sup>) but less than 39,889 gal (151 m<sup>3</sup>) and the liquid~~

~~stored has a maximum true vapor pressure less than 2.18 psia (15.0 kPa).~~

~~(C) The storage capacity is greater than or equal to 39,889 gal (151 m<sup>3</sup>) and the liquid stored has a maximum true vapor pressure less than 0.51 psia (3.5 kPa).~~

~~(3) The facility is designed to have a throughput of 19,998 gal/d (75,700 l/d) or less from the aggregate loading pipes.~~

~~(4) The facility meets the requirements of 252:100-7-60(a), (b), and (c).~~

**252:100-37-42. Permit-by-rule requirements [REVOKED]**

~~(a) An owner or operator shall submit annual emission inventory reports and meet the requirements of 252:100-37-5, regarding operation and maintenance, and 252:100-37-38, regarding pumps and compressors.~~

~~(b) No owner or operator shall build or install a new stationary VOC storage vessel with a capacity of 400 gal (1.5 m<sup>3</sup>) or greater unless it is equipped with a permanent submerged fill pipe as defined in 252:100-37-2.~~

~~(c) No owner or operator shall build or install a stationary VOC loading facility unless each loading pipe is equipped with a system for submerged filling of tank trucks or trailers which is installed and operated to maintain a 97 percent submergence factor.~~

~~(d) The owner or operator of a vessel with a storage capacity greater than 10,567 gal (40 m<sup>3</sup>) shall maintain records on site of the dimensions of the storage vessel and an analysis showing the capacity.~~