



**ACID RAIN PERMIT**

**AIR QUALITY DIVISION  
STATE OF OKLAHOMA  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
707 N. ROBINSON, SUITE 4100  
P.O. BOX 1677  
OKLAHOMA CITY, OKLAHOMA 73101-1677**

**Permit No.:** 2015-1874-ARR2 **Term :** 5 years

**Facility Name:** Oneta Power Facility **ORIS Code:** 55225

**Facility Location:** Broken Arrow, Wagoner County, Oklahoma

**Company Name:** Oneta Power, L.L.C

**Contact:** Edward Pete Convery, Asset Manager, (646) 634-8707

**Mailing Address:** 25142 East 105<sup>th</sup> Street South, Broken Arrow, OK 74014

This Permit is issued pursuant to **OAC 252:100-8-6.3** and **Title IV of the Clean Air Act** subject to the permit application attached by reference. The owner and operator of the source shall comply with the standard requirements and special provisions set forth in the permit application under 40 CFR 72.31. This permit is deemed to incorporate the definitions of terms under 40 CFR 72.2. Per 40 CFR 72.51, each affected unit operated in accordance with this permit shall be deemed to be operating in compliance with the Acid Rain Program, except as provided in 40 CFR 72.9(g)(6). The affected units will hold allowances in accordance with 40 CFR 72.9(c)(1) and allowances actually held by the facility may change as authorized.

<b>UNIT</b>	<b>Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)</b>	<b>Commence Operation Date</b>	<b>CEMS Certification Application Submittal Date</b>
CTG-1	Yes	6/1/2001	8/9/2002
CTG-2	Yes	6/1/2001	8/9/2002
CTG-3	Yes	6/1/2001	6/24/2003
CTG-4	Yes	6/1/2001	6/24/2003

\_\_\_\_\_  
**Director, Air Quality Division**

\_\_\_\_\_  
**Date**

**OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION**

**MEMORANDUM**

**March 17 2016**

**TO:** Phillip Fielder, P.E., Permits and Engineering Group Manager

**THROUGH:** Rick Groshong, Compliance and Enforcement Manager

**THROUGH:** Phil Martin, P.E., Engineering Section

**THROUGH:** Peer Review

**FROM:** Jian Yue, P.E., New Source Permits Section

**SUBJECT:** Evaluation of Permit Application No. **2015-1874-ARR2**  
Oneta Power, LLC.  
Oneta Power Facility (Facility ID: 3662)  
NE/4 Section 27, T18N, R15E  
Latitude: 36.008°, Longitude: -95.696°  
Broken Arrow, Wagoner County

**INTRODUCTION**

Oneta Power, LLC. has requested an acid rain permit renewal for the referenced facility pursuant to Title IV of the Clean Air Act and implementing regulations found in 40 CFR Parts 72 through 78. This facility is currently operating under Permit No. 2008-357-ARR, issued on May 18, 2009, which expired on May 17, 2014. 40 CFR 72.30(c) requires that the designated representative submit a complete Acid Rain permit application for each source with an affected unit at least 6 months prior to the expiration of an existing Acid Rain permit. The applicant submitted the renewal application on November 20, 2015. A referral has been made to the Compliance and Enforcement Section and the draft permit will go through enforcement review.

**TIER CLASSIFICATION AND PUBLIC REVIEW**

This application has been classified under Tier II as a new acid rain permit that is independent of a Part 70 permit application (252:4-7-33(b)(1)(E)). Information on all permit actions is available for review by the public in the Air Quality section of the DEQ Web Page: <http://www.deq.state.ok.us/>.

The applicant will publish a “Notice of Filing a Tier II Application” and a “Notice of Draft Permit” in a local newspaper for 30 days of public review. The permit is also proposed to EPA for a concurrent review. The facility is not located within 50 miles of the border of the state of Oklahoma and any other state.

**RATA TEST**

This facility shall comply with the emission monitoring and reporting requirements of Appendix D of 40 CFR Part 75. Appendix D requires an annual RATA. The following table lists the most recent tests conducted.

<b>Unit</b>	<b>Test Type</b>	<b>Test Dates</b>
CTG-01	RATA	August 4, 2015
CTG-02	RATA	August 5, 2015
CTG-03	RATA	August 6, 2015
CTG-04	RATA	August 7, 2015

**FEES PAID**

No fee is required for Acid Rain Permits.

**SUMMARY**

RATA tests have been performed according to 40 CFR Part 75 Appendix D. There are no active Compliance or Enforcement Air Quality issues concerning this facility. Issuance of the permit is recommended, contingent on public and EPA review.

Oneta Power LLC.  
Attn: Mr. Edward Pete Convery, Asset Manager  
25142 East 105<sup>th</sup> Street South  
Broken Arrow, OK 74014

SUBJECT: Acid Rain Permit No. 2015-1874-ARR2  
Oneta Power LLC  
Oneta Power Facility, Facility ID: 3662  
NE/4 Section 27, T18N, R15E, Wagoner County, OK

Dear Mr. Convery:

Air Quality Division has completed the initial review of your permit application referenced above. This application has been determined to be a **Tier II**. In accordance with 27A O.S. § 2-14-301 & 302 and OAC 252:4-7-13(c) the application and enclosed draft permit are now ready for public review. The requirements for public review include the following steps which you must accomplish:

1. Publish at least one legal notice (one day) of “Notice of Tier II Permit Application Filing” and “Notice of Tier II Draft Permit” in at least one newspaper of general circulation within the county where the facility is located. (Instructions enclosed)
2. Provide for public review (for a period of 30 days following the date of the newspaper announcement) a copy of this draft permit and a copy of the application at a convenient location (preferably a public location) within the county of the facility.
3. Send to AQD a copy of the proof of publication notice from Item #1 above together with any additional comments or requested changes which you may have on the draft permit.

Thank you for your cooperation. If you have any questions, please refer to the permit number above and contact me at (405) 702-4100 or the permit writer, Jian Yue, at (405) 702-4205.

Sincerely,

Phillip Fielder, P.E., Permits and Engineering Group Manager  
**AIR QUALITY DIVISION**  
Enclosures

Oneta Power LLC.  
Attn: Mr. Edward Pete Convery, Asset Manager  
25142 East 105<sup>th</sup> Street South  
Broken Arrow, OK 74014

SUBJECT: Acid Rain Permit No. 2015-1874-ARR2  
Oneta Power LLC  
Oneta Power Facility, Facility ID: 3662  
NE/4 Section 27, T18N, R15E, Wagoner County, OK

Dear Mr. Convery:

Enclosed is the permit authorizing operation of the referenced facility per 40 CFR 72.73.

Thank you for your cooperation in this matter. If we may be of further service, please contact our office at (405) 702-4100.

Very truly yours,

Jian Yue, P.E.  
Engineering Section  
AIR QUALITY DIVISION

enclosure

cc: EPA Region 6  
Compliance Assurance & Enforcement Division (6EN-AA)  
Attn: Mr. David Garcia  
1445 Ross Avenue  
Dallas, Texas 75202