

Lead in Schools Sample Results - Report

Facility ERICK ELEMENTARY SCHOOL



OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
6/16/2021	1-1-HALL-WC1	1-1-HALL-WC1-P-001	1.2	µg/L	1-1-HALL-WC1-F-002	13.7	µg/L
6/16/2021	1-1-HALL-WC2	1-1-HALL-WC2-P-001	11.0	µg/L	1-1-HALL-WC2-F-002	7.1	µg/L
6/16/2021	2-1-1ST-CF	2-1-1ST-CF-P-001	3.3	µg/L	2-1-1ST-CF-F-002	<1.0	µg/L
6/16/2021	2-1-1ST-DW	2-1-1ST-DW-P-001	4.7	µg/L	2-1-1ST-DW-F-002	4.1	µg/L
6/16/2021	2-1-2ND-CF	2-1-2ND-CF-P-001	3.2	µg/L	2-1-2ND-CF-F-002	1.2	µg/L
6/16/2021	2-1-3RD-CF	2-1-3RD-CF-P-001	4.1	µg/L	2-1-3RD-CF-F-002	<1.0	µg/L
6/16/2021	2-1-4TH-CF	2-1-4TH-CF-P-001	3.0	µg/L	2-1-4TH-CF-F-002	<1.0	µg/L
6/16/2021	2-1-5TH-CF	2-1-5TH-CF-P-001	1.5	µg/L	2-1-5TH-CF-F-002	<1.0	µg/L
6/16/2021	2-1-6TH-CF	2-1-6TH-CF-P-001	4.1	µg/L	2-1-6TH-CF-F-002	<1.0	µg/L
6/16/2021	2-1-HALL-WC1	2-1-HALL-WC1-P-001	<1.0	µg/L	2-1-HALL-WC1-F-002	<1.0	µg/L
6/16/2021	2-1-HALL-WC2	2-1-HALL-WC2-P-001	<1.0	µg/L	2-1-HALL-WC2-F-002	<1.0	µg/L
6/16/2021	2-1-HALL-WC	2-1-HALL-WC-P-001	2.7	µg/L	2-1-HALL-WC-F-002	3.0	µg/L
6/16/2021	2-1-KINDER-CF	2-1-KINDER-CF-P-001	1.1	µg/L	2-1-KINDER-CF-F-002	<1.0	µg/L
6/16/2021	2-1-KIT-KF	2-1-KIT-KF-P-001	9.3	µg/L	2-1-KIT-KF-F-002	1.8	µg/L
6/16/2021	2-1-LIB-CF	2-1-LIB-CF-P-001	2.3	µg/L	2-1-LIB-CF-F-002	<1.0	µg/L
6/16/2021	2-1-PREK-CF	2-1-PREK-CF-P-001	5.8	µg/L	2-1-PREK-CF-F-002	<1.0	µg/L
6/16/2021	3-1-ART-CF	3-1-ART-CF-P-001	4.7	µg/L	3-1-ART-CF-F-002	1.1	µg/L

Total 17