

Lead in Schools Sample Results - Report

Facility ERICK JUNIOR HIGH SCHOOL



OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
6/16/2021	1-1-KIT-KF1	1-1-KIT-KF1-P-001	18.1	µg/L	1-1-KIT-KF1-F-002	7.4	µg/L
6/16/2021	1-1-KIT-KF2	1-1-KIT-KF2-P-001	9.2	µg/L	1-1-KIT-KF2-F-002	6.7	µg/L
6/16/2021	2-1-6-CF1	2-1-6-CF1-P-001	37.5	µg/L	2-1-6-CF1-F-002	32.5	µg/L
6/16/2021	2-1-6-CF2	2-1-6-CF2-P-001	23.6	µg/L	2-1-6-CF2-F-002	99.1	µg/L
6/16/2021	2-1-HALL-WC1	2-1-HALL-WC1-P-001	2.6	µg/L	2-1-HALL-WC1-F-002	34.9	µg/L
6/16/2021	2-1-HALL-WC2	2-1-HALL-WC2-P-001	<1.0	µg/L	2-1-HALL-WC2-F-002	<1.0	µg/L
6/16/2021	2-1-HALL-WC3	2-1-HALL-WC3-P-001	<1.0	µg/L	2-1-HALL-WC3-F-002	<1.0	µg/L
6/16/2021	3-1-HALL-WC1	3-1-HALL-WC1-P-001	2.4	µg/L	3-1-HALL-WC1-F-002	2.6	µg/L
6/16/2021	3-1-HALL-WC2	3-1-HALL-WC2-P-001	<1.0	µg/L	3-1-HALL-WC2-F-002	<1.0	µg/L
6/16/2021	3-1-HALL-WC3	3-1-HALL-WC3-P-001	<1.0	µg/L	3-1-HALL-WC3-F-002	<1.0	µg/L
Total		10					