

2022 Water Rationing Report

SYSTEM	REASON	STATUS	RATION
Altus	Stage 1 water rationing.	Outside watering every other day, between 6 pm and 9 am.	V
Arapaho	Long-term drought conditions and per city council.	Outside water use one day per week per household.	M
Blanchard	Water line from OKC supply at Canadian River washed out in May 2015 flood. Currently purchasing water from Newcastle.	No outside watering.	M
Bridgeport	The PWS is requesting water conservation while the elevated storage tank is out of service following freeze damage	The tank will be repaired once funding is secured. (Funding is in process.) A contractor is ready to perform repairs.	V
Canadian Co. Water Authority	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Comanche PWA	Low lake levels.	The City has asked customers to participate in voluntary water rationing.	V
Cotton Co RWD #2	Well out of service for repairs	The district is asking customers to refrain from filling swimming pools and outdoor watering.	V
Deer Creek Rural Water Corp.	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Duncan	Low lake levels	Stage 5 - Outside water usage prohibited	M
Edmond PWA	PWS includes water purchased from OKC	Permanent water restrictions. Odd/even outdoor watering schedule	M
EI Reno	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Frederick	Long-term drought conditions.	Odd/even outdoor watering, with no outdoor watering on Sundays.	M

Rationing Type Key: M=mandatory rationing, V=voluntary rationing, S=suspend rationing, \$=surcharge

<i>SYSTEM</i>	<i>REASON</i>	<i>STATUS</i>	<i>RATION</i>
Guymon	Due to two wells being temporarily down the system was unable to keep up with the high demand.	The system is requesting voluntary rationing from customers.	V
Kiowa	Raw water pump and treatment plant issues	Town requesting voluntary water rationing	V
Lone Chimney	Now have consistent supply from Stillwater.	The water district is asking residential customers to use voluntary rationing when possible.	V
McAlester PWA	Treated water shortage following major line break and partial draining of storage towers	Customers asked to conserve water	V
Moore	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Mustang	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Newcastle	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Newkirk	West River Well inoperable due to mechanical failure while Central Well remains offline.	No bulk water sales. Outside watering on odd/even basis. No filling of swimming pools.	M
Norman	Increased water demand and raw water pump outage at Lake Thunderbird. Continuous need to limit water usage considering the supply limitations of the City's water sources.	In addition to mandatory restrictions. City of Norman is requesting voluntary water conservation. Permanent mandatory water restrictions are per City Ordinance 21-501. Year-round odd/even outdoor watering schedule.	M
Oklahoma City	Progressive water conservation measures approved by the city council, to lessen impact on the city's water supply reservoirs.	Permanent water restrictions. Stage 1 odd/even outdoor watering schedule has been implemented.	M

Rationing Type Key: M=mandatory rationing, V=voluntary rationing, S=suspend rationing, \$=surcharge

<i>SYSTEM</i>	<i>REASON</i>	<i>STATUS</i>	<i>RATION</i>
Optima	Groundwater well maintenance and capacity issues	Odd/Even outside watering. No new customers at this time.	V
Pawnee RWD #2	Water supplier has implemented water rationing.	Mandatory water rationing has been implemented. The district is also in the process of seeking out other water sources.	M
Pawnee RWD #3	Water supplier has implemented water rationing.	Mandatory water rationing has been implemented.	M
Pawnee RWD #4	Water supplier has implemented water rationing.	Mandatory water rationing has been implemented.	M
Payne RWD #4	Water supplier has implemented water rationing.	Mandatory water rationing has been implemented.	M
Piedmont	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Tinker Air Force Base	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M
Wapanucka	Low supply from source.	City is requesting that citizens conserve water.	V
Yale	Water supplier has implemented water rationing.	Mandatory water rationing has been implemented.	M
Yukon	Water purchased from OKC.	Permanent water restrictions. Odd/even outdoor watering schedule.	M

Rationing Type Key: M=mandatory rationing, V=voluntary rationing, S=suspend rationing, \$=surcharge