

Lead in Schools Sample Results - Report

Facility Townsend Elementary



Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
6/9/2022	1-1-12-CF	1-1-12-CF-P-001	1.1	µg/L	1-1-12-CF-F-002	<1.0	µg/L
6/9/2022	1-1-12-DW	1-1-12-DW-P-001	3.7	µg/L	1-1-12-DW-F-002	<1.0	µg/L
6/9/2022	1-1-14-CF	1-1-14-CF-P-001	6.2	µg/L	1-1-14-CF-F-002	1.6	µg/L
5/19/2023	1-1-14-CF	1-1-14-CF-P-003	14.5	µg/L	1-1-14-CF-F-004	1.4	µg/L
6/9/2022	1-1-14-DW	1-1-14-DW-P-001	3.3	µg/L	1-1-14-DW-F-002	1.8	µg/L
6/9/2022	1-1-15-CF	1-1-15-CF-P-001	<1.0	µg/L	1-1-15-CF-F-002	<1.0	µg/L
6/9/2022	1-1-15-DW	1-1-15-DW-P-001	1.8	µg/L	1-1-15-DW-F-002	<1.0	µg/L
6/9/2022	1-1-16-CF	1-1-16-CF-P-001	3.1	µg/L	1-1-16-CF-F-002	1.9	µg/L
6/9/2022	1-1-16-DW	1-1-16-DW-P-001	3.6	µg/L	1-1-16-DW-F-002	3.3	µg/L
6/9/2022	1-1-16-IM	1-1-16-IM-P-001	<1.0	µg/L	1-1-16-IM-F-002	<1.0	µg/L
6/9/2022	1-1-17-CF	1-1-17-CF-P-001	7.7	µg/L	1-1-17-CF-F-002	2.3	µg/L
5/19/2023	1-1-17-CF	1-1-17-CF-P-003	30.4	µg/L	1-1-17-CF-F-004	2.0	µg/L
6/9/2022	1-1-17-DW	1-1-17-DW-P-001	2.6	µg/L	1-1-17-DW-F-002	2.4	µg/L
6/9/2022	1-1-18-CF	1-1-18-CF-P-001	13.1	µg/L	1-1-18-CF-F-002	1.2	µg/L
5/19/2023	1-1-18-CF	1-1-18-CF-P-003	1.2	µg/L	1-1-18-CF-F-004	<1.0	µg/L
6/9/2022	1-1-18-DW	1-1-18-DW-P-001	27.3	µg/L	1-1-18-DW-F-002	5.6	µg/L
5/19/2023	1-1-18-DW	1-1-18-DW-P-003	<1.0	µg/L	1-1-18-DW-F-004	<1.0	µg/L
6/9/2022	1-1-19-CF	1-1-19-CF-P-001	5.5	µg/L	1-1-19-CF-F-002	2.0	µg/L
5/19/2023	1-1-19-CF	1-1-19-CF-P-003	13.1	µg/L	1-1-19-CF-F-004	1.3	µg/L
6/9/2022	1-1-19-DW	1-1-19-DW-P-001	3.0	µg/L	1-1-19-DW-F-002	1.9	µg/L
6/9/2022	1-1-20-CF	1-1-20-CF-P-001	8.7	µg/L	1-1-20-CF-F-002	1.6	µg/L
5/19/2023	1-1-20-CF	1-1-20-CF-P-003	2.9	µg/L	1-1-20-CF-F-004	<1.0	µg/L
6/9/2022	1-1-20-DW	1-1-20-DW-P-001	3.6	µg/L	1-1-20-DW-F-002	1.8	µg/L
6/9/2022	1-1-24-CF	1-1-24-CF-P-001	6.4	µg/L	1-1-24-CF-F-002	1.6	µg/L
5/19/2023	1-1-24-CF	1-1-24-CF-P-003	5.1	µg/L	1-1-24-CF-F-004	<1.0	µg/L
6/9/2022	1-1-24-DW	1-1-24-DW-P-001	3.0	µg/L	1-1-24-DW-F-002	1.7	µg/L
6/9/2022	1-1-25-CF	1-1-25-CF-P-001	8.2	µg/L	1-1-25-CF-F-002	1.8	µg/L
5/19/2023	1-1-25-CF	1-1-25-CF-P-003	3.3	µg/L	1-1-25-CF-F-004	<1.0	µg/L

Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
6/9/2022	1-1-25-DW	1-1-25-DW-P-001	2.9	µg/L	1-1-25-DW-F-002	1.9	µg/L
6/9/2022	1-1-26-CF	1-1-26-CF-P-001	1.6	µg/L	1-1-26-CF-F-002	<1.0	µg/L
6/9/2022	1-1-26-DW	1-1-26-DW-P-001	8.5	µg/L	1-1-26-DW-F-002	<1.0	µg/L
5/19/2023	1-1-26-DW	1-1-26-DW-P-003	3.5	µg/L	1-1-26-DW-F-004	<1.0	µg/L
6/9/2022	1-1-27-CF	1-1-27-CF-P-001	7.4	µg/L	1-1-27-CF-F-002	<1.0	µg/L
5/19/2023	1-1-27-CF	1-1-27-CF-P-003	4.8	µg/L	1-1-27-CF-F-004	<1.0	µg/L
6/9/2022	1-1-27-DW	1-1-27-DW-P-001	1.5	µg/L	1-1-27-DW-F-002	<1.0	µg/L
6/9/2022	1-1-28-CF	1-1-28-CF-P-001	1.4	µg/L	1-1-28-CF-F-002	1.1	µg/L
6/9/2022	1-1-28-DW	1-1-28-DW-P-001	<1.0	µg/L	1-1-28-DW-F-002	1.3	µg/L
6/9/2022	1-1-29BA-BF	1-1-29BA-BF-P-001	1.5	µg/L	1-1-29BA-BF-F-002	<1.0	µg/L
6/9/2022	1-1-29BA-DW	1-1-29BA-DW-P-001	<1.0	µg/L	1-1-29BA-DW-F-002	2.7	µg/L
6/9/2022	1-1-29-CF	1-1-29-CF-P-001	1.8	µg/L	1-1-29-CF-F-002	<1.0	µg/L
6/9/2022	1-1-29-DW	1-1-29-DW-P-001	1.1	µg/L	1-1-29-DW-F-002	1.3	µg/L
6/9/2022	1-1-30-CF	1-1-30-CF-P-001	1.8	µg/L	1-1-30-CF-F-002	<1.0	µg/L
6/9/2022	1-1-30-DW	1-1-30-DW-P-001	1.5	µg/L	1-1-30-DW-F-002	<1.0	µg/L
6/9/2022	1-1-32-CF	1-1-32-CF-P-001	5.6	µg/L	1-1-32-CF-F-002	2.4	µg/L
5/19/2023	1-1-32-CF	1-1-32-CF-P-003	3.2	µg/L	1-1-32-CF-F-004	1.3	µg/L
6/9/2022	1-1-32-DW	1-1-32-DW-P-001	2.2	µg/L	1-1-32-DW-F-002	2.2	µg/L
6/9/2022	1-1-36-CF	1-1-36-CF-P-001	3.2	µg/L	1-1-36-CF-F-002	1.5	µg/L
6/9/2022	1-1-36-DW	1-1-36-DW-P-001	1.4	µg/L	1-1-36-DW-F-002	1.4	µg/L
6/9/2022	1-1-38-CF	1-1-38-CF-P-001	2.6	µg/L	1-1-38-CF-F-002	1.7	µg/L
6/9/2022	1-1-38-DW	1-1-38-DW-P-001	2.5	µg/L	1-1-38-DW-F-002	2.5	µg/L
6/9/2022	1-1-39-CF	1-1-39-CF-P-001	4.1	µg/L	1-1-39-CF-F-002	2.3	µg/L
6/9/2022	1-1-39-DW	1-1-39-DW-P-001	1.6	µg/L	1-1-39-DW-F-002	2.2	µg/L
6/9/2022	1-1-40-CF	1-1-40-CF-P-001	8.7	µg/L	1-1-40-CF-F-002	1.6	µg/L
5/19/2023	1-1-40-CF	1-1-40-CF-P-003	4.7	µg/L	1-1-40-CF-F-004	1.2	µg/L
6/9/2022	1-1-40-DW	1-1-40-DW-P-001	1.6	µg/L	1-1-40-DW-F-002	1.8	µg/L
6/9/2022	1-1-41-CF	1-1-41-CF-P-001	4.7	µg/L	1-1-41-CF-F-002	1.7	µg/L
6/9/2022	1-1-41-DW	1-1-41-DW-P-001	1.5	µg/L	1-1-41-DW-F-002	1.8	µg/L
6/9/2022	1-1-43-CF	1-1-43-CF-P-001	2.8	µg/L	1-1-43-CF-F-002	1.7	µg/L
6/9/2022	1-1-43-DW	1-1-43-DW-P-001	1.7	µg/L	1-1-43-DW-F-002	1.9	µg/L
6/9/2022	1-1-44-CF	1-1-44-CF-P-001	6.8	µg/L	1-1-44-CF-F-002	4.0	µg/L

Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
5/19/2023	1-1-44-CF	1-1-44-CF-P-003	8.0	µg/L	1-1-44-CF-F-004	3.5	µg/L
6/9/2022	1-1-44-DW	1-1-44-DW-P-001	20.7	µg/L	1-1-44-DW-F-002	5.2	µg/L
5/19/2023	1-1-44-DW	1-1-44-DW-P-003	23.4	µg/L	1-1-44-DW-F-004	7.4	µg/L
6/9/2022	1-1-45-CF	1-1-45-CF-P-001	7.8	µg/L	1-1-45-CF-F-002	3.3	µg/L
5/19/2023	1-1-45-CF	1-1-45-CF-P-003	7.7	µg/L	1-1-45-CF-F-004	3.9	µg/L
6/9/2022	1-1-45-DW	1-1-45-DW-P-001	4.2	µg/L	1-1-45-DW-F-002	3.8	µg/L
6/9/2022	1-1-46-CF	1-1-46-CF-P-001	15.8	µg/L	1-1-46-CF-F-002	4.1	µg/L
5/19/2023	1-1-46-CF	1-1-46-CF-P-003	8.3	µg/L	1-1-46-CF-F-004	3.3	µg/L
6/9/2022	1-1-46-DW	1-1-46-DW-P-001	4.3	µg/L	1-1-46-DW-F-002	3.6	µg/L
6/9/2022	1-1-47-CF	1-1-47-CF-P-001	12.8	µg/L	1-1-47-CF-F-002	2.8	µg/L
5/19/2023	1-1-47-CF	1-1-47-CF-P-003	11.1	µg/L	1-1-47-CF-F-004	3.2	µg/L
6/9/2022	1-1-47-DW	1-1-47-DW-P-001	3.7	µg/L	1-1-47-DW-F-002	2.9	µg/L
6/9/2022	1-1-48-CF	1-1-48-CF-P-001	11.8	µg/L	1-1-48-CF-F-002	4.1	µg/L
5/19/2023	1-1-48-CF	1-1-48-CF-P-003	9.4	µg/L	1-1-48-CF-F-004	3.7	µg/L
6/9/2022	1-1-48-DW	1-1-48-DW-P-001	4.5	µg/L	1-1-48-DW-F-002	3.7	µg/L
6/9/2022	1-1-57-CF	1-1-57-CF-P-001	1.7	µg/L	1-1-57-CF-F-002	1.3	µg/L
6/9/2022	1-1-57-DW	1-1-57-DW-P-001	<1.0	µg/L	1-1-57-DW-F-002	<1.0	µg/L
6/9/2022	1-1-58-CF	1-1-58-CF-P-001	1.0	µg/L	1-1-58-CF-F-002	<1.0	µg/L
6/9/2022	1-1-58-DW	1-1-58-DW-P-001	<1.0	µg/L	1-1-58-DW-F-002	<1.0	µg/L
6/9/2022	1-1-59-CF	1-1-59-CF-P-001	<1.0	µg/L	1-1-59-CF-F-002	<1.0	µg/L
6/9/2022	1-1-59-DW	1-1-59-DW-P-001	<1.0	µg/L	1-1-59-DW-F-002	<1.0	µg/L
6/9/2022	1-1-7-CF	1-1-7-CF-P-001	1.5	µg/L	1-1-7-CF-F-002	1.6	µg/L
6/9/2022	1-1-7-DW	1-1-7-DW-P-001	8.2	µg/L	1-1-7-DW-F-002	2.0	µg/L
5/19/2023	1-1-7-DW	1-1-7-DW-P-003	2.8	µg/L	1-1-7-DW-F-004	<1.0	µg/L
6/9/2022	1-1-8-CF	1-1-8-CF-P-001	<1.0	µg/L	1-1-8-CF-F-002	<1.0	µg/L
6/9/2022	1-1-9-CF	1-1-9-CF-P-001	1.2	µg/L	1-1-9-CF-F-002	<1.0	µg/L
6/9/2022	1-1-9-DW	1-1-9-DW-P-001	1.7	µg/L	1-1-9-DW-F-002	<1.0	µg/L
6/9/2022	1-1-CAFE-WC	1-1-CAFE-WC-P-001	4.8	µg/L	1-1-CAFE-WC-F-002	5.8	µg/L
5/19/2023	1-1-CAFE-WC	1-1-CAFE-WC-P-003	1.5	µg/L	1-1-CAFE-WC-F-004	1.7	µg/L
6/9/2022	1-1-GYM-W2	1-1-GYM-W2-P-001	1.4	µg/L	1-1-GYM-W2-F-002	1.9	µg/L
6/9/2022	1-1-GYM-WC1	1-1-GYM-WC1-P-001	1.4	µg/L	1-1-GYM-WC1-F-002	1.3	µg/L
6/9/2022	1-1-HALL-WC10	1-1-HALL-WC10-P-001	<1.0	µg/L	1-1-HALL-WC10-F-002	1.1	µg/L

Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
6/9/2022	1-1-HALL-WC3	1-1-HALL-WC3-P-001	<1.0	µg/L	1-1-HALL-WC3-F-002	<1.0	µg/L
6/9/2022	1-1-HALL-WC4	1-1-HALL-WC4-P-001	<1.0	µg/L	1-1-HALL-WC4-F-002	<1.0	µg/L
6/9/2022	1-1-HALL-WC5	1-1-HALL-WC5-P-001	<1.0	µg/L	1-1-HALL-WC5-F-002	<1.0	µg/L
6/9/2022	1-1-HALL-WC6	1-1-HALL-WC6-P-001	<1.0	µg/L	1-1-HALL-WC6-F-002	<1.0	µg/L
6/9/2022	1-1-HALL-WC7	1-1-HALL-WC7-P-001	1.3	µg/L	1-1-HALL-WC7-F-002	1.2	µg/L
6/9/2022	1-1-HALL-WC8	1-1-HALL-WC8-P-001	1.2	µg/L	1-1-HALL-WC8-F-002	1.3	µg/L
6/9/2022	1-1-HALL-WC9	1-1-HALL-WC9-P-001	1.3	µg/L	1-1-HALL-WC9-F-002	1.5	µg/L
6/9/2022	1-1-KITCH-KF1	1-1-KITCH-KF1-P-001	9.5	µg/L	1-1-KITCH-KF1-F-002	1.1	µg/L
5/19/2023	1-1-KITCH-KF1	1-1-KITCH-KF1-P-003	10.6	µg/L	1-1-KITCH-KF1-F-004	<1.0	µg/L
6/9/2022	1-1-KITCH-KF2	1-1-KITCH-KF2-P-001	2.7	µg/L	1-1-KITCH-KF2-F-002	1.2	µg/L
6/9/2022	1-1-NURSE-NS	1-1-NURSE-NS-P-001	3.0	µg/L	1-1-NURSE-NS-F-002	1.2	µg/L
6/9/2022	2-1-MEDIA-KF	2-1-MEDIA-KF-P-001	<1.0	µg/L	2-1-MEDIA-KF-F-002	<1.0	µg/L
6/9/2022	2-1-MEDIA-WC1	2-1-MEDIA-WC1-P-001	1.1	µg/L	2-1-MEDIA-WC1-F-002	1.6	µg/L
6/9/2022	2-1-MEDIA-WC2	2-1-MEDIA-WC2-P-001	1.6	µg/L	2-1-MEDIA-WC2-F-002	2.1	µg/L

Total 106