



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of OKC

School: Garden Diggs Head Start

Sampling Date: 8/20/2024

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Community Action Agency of OKC - Garden Diggs Head Start on August 20, 2024. Overall, eight (8) outlets were tested resulting in a total of sixteen (16) samples being sent to the lab.

- Ten (10) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-BR-BF1	Bathroom faucet in boys' restroom; left side	<1.0	<1.0	N/A
1-1-BR-BF2	Bathroom faucet in boys' restroom; right side	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in facility kitchen; double sink; left side	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF3	Kitchen faucet in facility kitchen; double sink; right side	1.42	<1.0	
1-1-GR-BF2	Bathroom faucet in girls' restroom; right side	1.63	<1.0	
1-1-KIT-KF1	Kitchen faucet in facility kitchen; standalone sink near door	2.08	<1.0	
1-1-A-WC1	Elkay water cooler in Classroom A	1.25	3.5	
1-1-GR-BF1	Bathroom faucet in girls' restroom; left side	5.29	<1.0	