



District: Community Action Agency of Oklahoma City
 School: Carolyn Shaw Head Start
 Sampling Date: 8/20/2024
 Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Community Action Agency of Oklahoma City - Carolyn Shaw Head Start on August 20, 2024. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Seven (7) samples had no detectable level of lead.
- Thirteen (13) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Elkay bottle filler in main hallway	<1.0	<1.0	N/A
1-1-HALL-WC2	Elkay water cooler in main hallway	<1.0	<1.0	N/A
1-1-KIT-IM1	Manitowoc ice machine in facility kitchen; brass-looking filter valve	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-GR-BF2	Bathroom faucet in girls' restroom; right side	<1.0	1.3	
1-1-BR-BF2	Bathroom faucet in boys' bathroom; right side	1.5	1.2	
1-1-GR-BF1	Bathroom faucet in girls' restroom; left side	1.8	1.1	
1-1-2-CF1	Classroom faucet in Classroom 2	3.7	1.3	
1-1-BR-BF1	Bathroom faucet in boys' bathroom; left side	3.7	1.9	
1-1-1-CF1	Classroom faucet in Classroom 1; right side	8.7	1.9	
1-1-1-CF2	Classroom faucet in Classroom 1; left side	10.7	2.0	