



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: C.A.R.D. Head Starts

School: Southside Head Start

Sampling Dates: 8/2/2023, 9/17/2024

Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at C.A.R.D. Head Starts - Southside Head Start. The initial sampling event occurred on August 2, 2023. The resampling event occurred on September 17, 2024.

In the initial sampling, eighteen (18) outlets were tested resulting in a total of thirty-six (36) samples being sent to the lab.

- Nine (9) samples had no detectable level of lead.
- Eighteen (18) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Nine (9) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Fifteen (15) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-6-KF1	Kitchen faucet in early head start room	<1.0	<1.0	N/A	<1.0	<1.0
1-1-6-CF1	Classroom faucet in early head start room; used for handwashing for babies	<1.0	<1.0	N/A	<1.0	<1.0
1-1-TRAIN-IM1	Manitowoc ice machine in training area	<1.0	<1.0	N/A	<1.0	<1.0
1-1-KIT-KF2	Kitchen faucet in facility kitchen; handwashing sink	N/A	N/A	New	<1.0	<1.0
1-1-6-KF2	Kitchen faucet in Rm 6	N/A	N/A	New	<1.0	<1.0

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-TRAIN-KF1	Kitchen faucet in training area	1.8	<1.0		<1.0	<1.0
1-1-GYM-WC1	Elkay water cooler in gym; left of handwashing sink	2	3.3	Removed		
1-1-GYM-WC1	Elkay water cooler in gym; left of handwashing sink	2	3.3	Removed		
1-1-HALL-WC4	Water cooler in 4-year-old hallway; near Rm 11	7.9	8.9	Removed		
1-1-GYM-CF4	Classroom faucet in gym; right most handwashing sink	11.1	2.9	Removed		
1-1-GYM-CF2	Classroom faucet in gym; left center handwashing sink	12.8	4.8	Removed		
1-1-HALL-WC3	Water cooler in 3-year-old hallway; near Rm 3; left side	8.2	15.8	Removed		
1-1-GYM-CF3	Classroom faucet in gym; right center handwashing sink	16.2	2.2	Removed		
1-1-HALL-DW1	Drinking water fountain in 3- year-old hallway; near Rm 6; right side	17.1	7.6	Removed		
1-1-GYM-CF1	Classroom faucet in gym; left most handwashing sink	17.5	5.3	Removed		
1-1-HALL-WC2	Water cooler in 3-year-old hallway; near Rm 6; left side	6.7	18.9	Removed		
1-1-HALL-DW2	Water cooler in 3-year-old hallway; near Rm 3; right side	31.7	8.6	Removed		
1-1-HALL-WC1	Sunroe Corp water cooler in 3-year-old hallway	19.2	40.6	Removed		
Low Detection (1.0 - 14.9 µg/L)						
1-1-KIT -KF1	Kitchen faucet in facility kitchen; 3-compartment sink	<1.0	1.3			
1-1-4-CF1	Classroom faucet in Rm 4	N/A	N/A	New	1.4	<1.0
1-1-TL-KF1	Kitchen faucet in teachers' lounge	1.2	<1.0		1.6	<1.0

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-5-CF1	Classroom faucet in Rm 5	N/A	N/A	New	2.7	<1.0
1-1-SR-CF1	Classroom faucet in sensory room	N/A	N/A	New	3.0	1.6
High Detection (≥15.0 µg/L)						
1-1-KIT -KF2	Kitchen faucet in facility kitchen; handwashing sink	17.9	2.1	Handwash ONLY		