



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Jones Public Schools

School: Jones Middle School

Sampling Dates: 12/18/2024, 4/2/2025

Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Jones Public Schools – Jones Middle School. The initial sampling event occurred on December 18, 2024. The resampling event occurred on April 2, 2025.

In the initial sampling, twenty-eight (28) outlets were tested resulting in a total of fifty-six (56) samples being sent to the lab.

- Fifty-two (52) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, four (4) outlets were tested resulting in a total of eight (8) samples being sent to the lab.

- Five (5) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-BRR-BF1	Bathroom faucet in boys' restroom of 6th/7th grade hall; across from library; left side	<1.0	<1.0	N/A		
1-1-BRR-BF2	Bathroom faucet in boys' restroom of 6th/7th grade hall; across from library; right side	<1.0	<1.0	N/A		
1-1-HALL-WC1	Elkay water cooler with bottle filler in 6th/7th grade hall; across from library; near boys' restroom	<1.0	<1.0	N/A		
1-1-HALL-WC2	Elkay bottle filler in 6th/7th grade hall; across from library; near boys' restroom	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-GRR-BF1	Bathroom faucet in girls' restroom of 6th/7th grade hall; across from library; left side	<1.0	<1.0	N/A		
1-1-GRR-BF2	Bathroom faucet in girls' restroom of 6th/7th grade hall; across from library; right side	<1.0	<1.0	N/A		
1-1-LIB-BF1	Bathroom faucet in boys' restroom in library	<1.0	<1.0	N/A		
1-1-LIB-BF2	Bathroom faucet in girls' restroom in library	<1.0	<1.0	N/A		
1-1-HALL-WC4	Elkay water cooler with bottle filler in 8th grade hall; near boys' restroom	<1.0	<1.0	N/A		
1-1-HALL-WC5	Elkay bottle filler in 8th grade hall; near boys' restroom	<1.0	<1.0	N/A		
1-1-BRR-BF3	Bathroom faucet in boys' restroom; in 8th grade hall; left side	<1.0	<1.0	N/A		
1-1-BRR-BF4	Bathroom faucet in boys' restroom; in 8th grade hall; right side	<1.0	<1.0	N/A		
1-1-GRR-BF3	Bathroom faucet in girls' restroom; in 8th grade hall; left side	<1.0	<1.0	N/A		
1-1-GRR-BF4	Bathroom faucet in girls' restroom; in 8th grade hall; left side	<1.0	<1.0	N/A		
1-1-BRR-BF5	Bathroom faucet in boys' restroom; near main office and cafeteria	<1.0	<1.0	N/A		
1-1-GRR-BF6	Bathroom faucet in girls' restroom; near main office and cafeteria; right side	<1.0	<1.0	N/A		
1-1-GRR-BF7	Bathroom faucet in girls' restroom; near main office and cafeteria; left side	<1.0	<1.0	N/A		
1-1-HALL-WC6	Elkay water cooler with bottle filler in hall; near main office and cafeteria	<1.0	<1.0	N/A		
1-1-HALL-WC7	Elkay bottle filler in hall; near main office and cafeteria	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-SRR-BF1	Bathroom faucet in staff restroom; near main office and cafeteria	<1.0	<1.0	N/A		
1-1-TL-KF1	Kitchen faucet in teachers' lounge/workroom	<1.0	<1.0	N/A		
1-1-TL-IM1	Ice machine in teachers' lounge/workroom	<1.0	<1.0	N/A		
1-1-KIT-KF1	Kitchen faucet in facility kitchen; handwash sink	<1.0	<1.0	N/A		
1-1-KIT-KF2	Kitchen faucet in facility kitchen; 3-compartment sink; left side	<1.0	<1.0	N/A		
1-1-KIT-KF3	Kitchen faucet in facility kitchen; 3-compartment sink; right side	1.7	<1.0		<1.0	<1.0
Low Detection (1.0 - 14.9 µg/L)						
1-1-GYM-BF1	Bathroom faucet in girls' locker room; at back of gym	2.5	<1.0		5.3	<1.0
1-1-GYM-BF2	Bathroom faucet in boys' locker room; at back of gym	1.9	<1.0		3.8	<1.0
1-1-GRR-BF5	Bathroom faucet in girls' restroom; in 8th grade hall; right side	2.1	<1.0		1.3	<1.0