

# Lead in Schools Sample Results - Report

Facility MCLISH MIDDLE SCHOOL (STONEWALL)



Sampling Date	Outlet Code	First Draw			30 Second Draw		
		Sample ID	Result	Units	Sample ID	Result	Units
10/21/2021	1-1-CAFE-IM	1-1-CAFE-IM-P-001	<1.0	µg/L	1-1-CAFE-IM-F-002	<1.0	µg/L
10/21/2021	1-1-CONC-KF	1-1-CONC-KF-P-001	2.0	µg/L	1-1-CONC-KF-F-002	<1.0	µg/L
10/21/2021	1-1-KIT-KF1	1-1-KIT-KF1-P-001	1.1	µg/L	1-1-KIT-KF1-F-002	<1.0	µg/L
10/21/2021	1-1-KIT-KF2	1-1-KIT-KF2-P-001	1.9	µg/L	1-1-KIT-KF2-F-002	<1.0	µg/L
10/21/2021	2-1-HALL-WC1	2-1-HALL-WC1-P-001	<1.0	µg/L	2-1-HALL-WC1-F-002	<1.0	µg/L
10/21/2021	2-1-HALL-WC2	2-1-HALL-WC2-P-001	<1.0	µg/L	2-1-HALL-WC2-F-002	1.0	µg/L
10/21/2021	3-1-CONC-KF	3-1-CONC-KF-P-001	15.2	µg/L	3-1-CONC-KF-F-002	1.5	µg/L
11/18/2022	3-1-CONC-KF	3-1-CONC-KF-P-003	81.5	µg/L	3-1-CONC-KF-F-004	8.7	µg/L
10/21/2021	3-1-GYM-WC1	3-1-GYM-WC1-P-001	<1.0	µg/L	3-1-GYM-WC1-F-002	<1.0	µg/L
10/21/2021	3-1-GYM-WC2	3-1-GYM-WC2-P-001	<1.0	µg/L	3-1-GYM-WC2-F-002	<1.0	µg/L
10/21/2021	4-1-LIB-WC	4-1-LIB-WC-P-001	3.3	µg/L	4-1-LIB-WC-F-002	2.5	µg/L
10/21/2021	5-1-STEM-CF	5-1-STEM-CF-P-001	14.0	µg/L	5-1-STEM-CF-F-002	1.5	µg/L
10/21/2021	6-1-BARB-CF	6-1-BARB-CF-P-001	8.7	µg/L	6-1-BARB-CF-F-002	1.3	µg/L
10/21/2021	6-1-CART-CF	6-1-CART-CF-P-001	4.9	µg/L	6-1-CART-CF-F-002	<1.0	µg/L
10/21/2021	6-1-PREK-WC1	6-1-PREK-WC1-P-001	<1.0	µg/L	6-1-PREK-WC1-F-002	<1.0	µg/L
10/21/2021	6-1-PREK-WC2	6-1-PREK-WC2-P-001	1.8	µg/L	6-1-PREK-WC2-F-002	1.7	µg/L
Total		16					