



District: Southwest Oklahoma Community Action Group

School: Mangum Head Start

Sampling Date: 10/24/2024

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Southwest Oklahoma Community Action Group - Mangum Head Start on October 24, 2024. Overall, six (6) outlets were tested resulting in a total of twelve (12) samples being sent to the lab.

- Eight (8) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF2	Kitchen faucet in facility kitchen; on back wall	<1.0	<1.0	N/A
1-1-RR-BF1	Bathroom faucet in facility restroom; right side	<1.0	<1.0	N/A
1-1-RR-BF2	Bathroom faucet in facility restroom; left side	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-BCR-BF1	Bathroom faucet in back classroom restroom	1.3	1.2	
1-1-KIT-KF1	Kitchen faucet in facility kitchen; at front of kitchen near entrance	1.4	<1.0	
1-1-BC-CF1	Classroom faucet in back classroom	1.5	<1.0	