



District: Southwest Oklahoma Community Action Group  
 School: Lincoln Center HeadStart  
 Sampling Date: 6/26/2024  
 Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Southwest Oklahoma Community Action Group - Lincoln Center HeadStart on June 26, 2024. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Seven (7) samples had no detectable level of lead.
- Twelve (12) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-FH-WC1	Elkay water cooler in front hall	<1.0	<1.0	N/A
1-1-FH-WC2	Elkay bottle filler in front hall	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF2	Kitchen faucet in facility kitchen; right side	1.7	1.1	
2-1-EH-CF2	Classroom faucet in Early HeadStart Room; right side; in temporary building	2.5	<1.0	
2-1-BB-CF1	Classroom faucet in baby room; in temporary building	3.0	1.0	
1-1-2-BF3	Bathroom faucet in Room 2 bathroom; right side	5.2	4.2	
2-1-EH-CF1	Classroom faucet in Early HeadStart Room; left side; in temporary building	5.3	<1.0	
1-1-2-BF2	Bathroom faucet in Room 2 bathroom; middle unit	9.2	2.6	
1-1-KIT-KF1	Kitchen faucet in facility kitchen; left side	11.7	<1.0	
High Detection (≥15.0 µg/L)				
1-1-2-BF1	Bathroom faucet in Room 2 bathroom; left side	18.9	2.8	