



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Sunbeam Family ServicesSchool: Millwood Early Education CenterSampling Date: 5/17/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - Millwood Early Education Center on May 17, 2024. Overall, eleven (11) outlets were tested resulting in a total of twenty-two (22) samples being sent to the lab.

- Twenty-one (21) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-TL-KF	Kitchen faucet in teachers' lounge	<1.0	<1.0	N/A
1-1-TL-IM	Manitowoc ice machine in teachers' lounge	<1.0	<1.0	N/A
1-1-A-CF1	Classroom faucet in Classroom A; left side	<1.0	<1.0	N/A
1-1-A-CF2	Classroom faucet in Classroom A; right side	<1.0	<1.0	N/A
1-1-B-CF1	Classroom faucet in Classroom B; left side	<1.0	<1.0	N/A
1-1-B-CF2	Classroom faucet in Classroom B; right side	<1.0	<1.0	N/A
1-1-B-BF	Bathroom faucet in Classroom B Bathroom	<1.0	<1.0	N/A
1-1-C-CF1	Classroom faucet in Classroom C; left side	<1.0	<1.0	N/A
1-1-C-CF2	Classroom faucet in Classroom C; right side	<1.0	<1.0	N/A
1-1-C-BF	Bathroom faucet in Classroom C Bathroom	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
1-1-A-BF	Bathroom faucet in Classroom A Bathroom	1.4	<1.0	