



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Tulsa Women &amp; Children CCC

School: Tulsa Women &amp; Children CCC

Sampling Date: 2/25/2025Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Tulsa Women & Children CCC - Tulsa Women & Children CCC on February 25, 2025.

Overall, thirty-four (34) outlets were tested resulting in a total of sixty-eight (68) samples being sent to the lab.

- Sixty-six (66) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Two (2) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-IR1-KF1	Kitchen faucet in Infant Room 1; Right side next to door	<1.0	<1.0	N/A
1-1-IR1-KF2	Kitchen faucet in Infant Room 1; left side	<1.0	<1.0	N/A
1-1-IR2-KF1	Kitchen faucet in Infant Room 2; left side	<1.0	<1.0	N/A
1-1-IR2-KF2	Kitchen faucet in Infant Room 2; right side	<1.0	<1.0	N/A
1-1-TR-KF1	Kitchen faucet in toddler room; outside bathroom	<1.0	<1.0	N/A
1-1-TR-BF1	Bathroom faucet in toddler room bathroom	<1.0	<1.0	N/A
1-1-SA-KF1	Kitchen faucet in School age classroom; outside bathroom	<1.0	<1.0	N/A
1-1-SA-BF1	Bathroom faucet in School age bathroom	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet in facility kitchen; next to dishwasher	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in facility kitchen; 3-compartment sink at back of kitchen	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen faucet in facility kitchen; on island near fryer	<1.0	<1.0	N/A
1-1-KIT-KF4	Kitchen faucet in facility kitchen; near cooler	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-BR-BF1	Bathroom faucet in facility bathroom; near Rooms E1 and E2	<1.0	<1.0	N/A
1-1-BR-BF2	Bathroom faucet in facility bathroom; near Rooms E1 and E2	<1.0	<1.0	N/A
1-1-BR-BF3	Bathroom faucet in facility bathroom; near Room E3	<1.0	<1.0	N/A
1-1-BR-KF1	Kitchen faucet near facility restroom; outside Room E8	<1.0	<1.0	N/A
1-1-BR-BF4	Bathroom faucet in Room E8 bathroom	<1.0	<1.0	N/A
1-1-BR-BF5	Bathroom faucet in Room E8 bathroom	<1.0	<1.0	N/A
1-1-BR-BF6	Bathroom faucet in Room E9 bathroom	<1.0	<1.0	N/A
1-1-BR-BF7	Bathroom faucet in Room E9 bathroom	<1.0	<1.0	N/A
1-1-BR-BF8	Bathroom faucet in Room W1 bathroom	<1.0	<1.0	N/A
1-1-BR-BF9	Bathroom faucet in Room W1 bathroom	<1.0	<1.0	N/A
1-1-BR-BF10	Bathroom faucet in Room W3 bathroom	<1.0	<1.0	N/A
1-1-BR-BF11	Bathroom faucet in Room W3 bathroom	<1.0	<1.0	N/A
1-1-BR-BF12	Bathroom faucet in Room W8 bathroom	<1.0	<1.0	N/A
1-1-BR-BF13	Bathroom faucet in Room W8 bathroom	<1.0	<1.0	N/A
1-1-BR-BF14	Bathroom faucet in Room W9 bathroom	<1.0	<1.0	N/A
1-1-BR-BF15	Bathroom faucet in Room W9 bathroom	<1.0	<1.0	N/A
1-1-CBR-BF1	Bathroom faucet in cafeteria bathroom; west side	<1.0	<1.0	N/A
1-1-CBR-BF2	Bathroom faucet in cafeteria bathroom; east side	<1.0	<1.0	N/A
1-1-LBR-BF1	Bathroom faucet in lobby bathroom; right side	<1.0	<1.0	N/A
1-1-LBR-BF2	Bathroom faucet in lobby bathroom; left side	<1.0	<1.0	N/A
<b>High Detection (≥15.0 µg/L)</b>				
1-1-Pre-KF1	Kitchen faucet in Preschool classroom; outside bathroom	<1.0	33.5	
1-1-Pre-BF1	Bathroom faucet in Preschool bathroom	85.2	<1.0	