



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Washita Valley Community Action CenterSchool: Anadarko Head Start CenterSampling Date: 10/23/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Washita Valley Community Action Center - Anadarko Head Start Center on October 23, 2024. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Thirteen (13) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet in facility kitchen; left side	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet in facility kitchen; right side	<1.0	<1.0	N/A
1-1-3-CF1	Classroom faucet in Rm 3	<1.0	<1.0	N/A
1-1-2-CF1	Classroom faucet in Rm 2	<1.0	<1.0	N/A
1-1-1-CF1	Classroom faucet in Rm 1	<1.0	<1.0	N/A
1-1-5-CF1	Classroom faucet in Rm 5	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-4-CF1	Classroom faucet in Rm 4	1.3	<1.0	