



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: LIFT Community Action Agency

School: Broken Bow Early Learning Center

Sampling Date: 9/21/2021

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at LIFT Community Action Agency - Broken Bow Early Learning Center on September 21, 2021. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF	Kitchen faucet in kitchen	<1.0	<1.0	N/A
2-1-RM3-CF	Classroom faucet in Room 3	<1.0	<1.0	N/A
2-1-HALL-KF	Kitchen faucet in hallway between classrooms; used for laundry and dishes	<1.0	<1.0	N/A
2-1-RM2-CF	Classroom faucet in Room 2; white sink	<1.0	<1.0	N/A
2-1-RM1-CF	Classroom faucet in Room 1; white sink	<1.0	<1.0	N/A
2-1-RM4-CF1	Classroom faucet in Room 4; right side	<1.0	<1.0	N/A
2-1-RM4-CF2	Classroom faucet in Room 4; left side	<1.0	<1.0	N/A