



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Colbert Public SchoolsSchool: Eastward ElementarySampling Date: 8/3/2021Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Colbert Public Schools - Eastward Elementary School on August 3, 2021. Overall, nine (9) outlets were tested resulting in a total of eighteen (18) samples being sent to the lab.

- Four (4) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Three (3) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-FRONT-WC1	Elkay water cooler; Near Room #2	<1.0	<1.0	N/A
1-1-FRONT-WC2	Elkay bottle filler; Near Room #2	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-SHALL-WC1	Elkay water cooler; Near Room #10 in South Hall; left of sinks	2.0	2.1	
1-1-NHALL-BF	Bathroom faucet in North hallway; left of Elkay water coolers	3.3	3.3	Restricted Access
1-1-GYM-WC	ELKAY water cooler in gym; by exit	9.3	1.9	
1-1-NHALL-WC	ELKAY water cooler; Near Room #5 in North Hall	10.5	2.9	
High Detection (≥15.0 µg/L)				
1-1-SHALL-BF2	Bathroom faucet in South hallways near Room #10; right side	16.3	2.3	Restricted Access
1-1-SHALL-BF1	Bathroom faucet in South hallways near Room #10; left side	26.7	1.9	Restricted Access
1-1-NHALL-CF	Classroom faucet in North Hall	53.1	4.2	Restricted Access