



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of OKCSchool: Mary Helen Nelson HeadStartSampling Date: 4/4/2024Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Community Action Agency of OKC - Mary Helen Nelson HeadStart on April 4, 2024. Overall, fifteen (15) outlets were tested resulting in a total of thirty (30) samples being sent to the lab.

- Twenty-nine (29) samples had no detectable level of lead.
- One (1) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID | Comments | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|------------------------|---|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| Non-Detect (<1.0 µg/L) | | | | |
| 1-1-HALL-WC1 | Elkay water cooler in first floor hallway; to right of stairs | <1.0 | <1.0 | N/A |
| 1-1-RR-BF1 | Bathroom faucet in boys' restroom on first floor; used for brushing teeth | <1.0 | <1.0 | N/A |
| 1-1-RR-BF2 | Bathroom faucet in girls' restroom on first floor; used for brushing teeth; left side | <1.0 | <1.0 | N/A |
| 1-1-RR-BF3 | Bathroom faucet in girls' restroom on first floor; used for brushing teeth; center sink | <1.0 | <1.0 | N/A |
| 1-1-RR-BF4 | Bathroom faucet in girls' restroom on first floor; used for brushing teeth; right side | <1.0 | <1.0 | N/A |
| 1-1-KIT-KF1 | Kitchen faucet in school kitchen; on left side of kitchen | <1.0 | <1.0 | N/A |
| 1-1-KIT-KF2 | Kitchen faucet in school kitchen; on right side of kitchen | <1.0 | <1.0 | N/A |
| 1-1-KIT-IM | Ice machine in school kitchen | <1.0 | <1.0 | N/A |
| 1-2-HALL-WC1 | Elkay water cooler outside Classroom C on second floor | <1.0 | <1.0 | N/A |
| 1-2-C-CF | Classroom faucet in Classroom C | <1.0 | <1.0 | N/A |

| Sample ID | Comments | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|--|---|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| 1-2-RR-BF1 | Bathroom faucet in second floor restroom; rightmost sink | <1.0 | <1.0 | N/A |
| 1-2-RR-BF2 | Bathroom faucet in second floor restroom; right side sink in set of three | <1.0 | <1.0 | N/A |
| 1-2-RR-BF3 | Bathroom faucet in second floor restroom; center sink in set of three | <1.0 | <1.0 | N/A |
| 1-2-RR-BF4 | Bathroom faucet in second floor restroom; left side sink in set of three | <1.0 | <1.0 | N/A |
| Low Detection (1.0 - 14.9 µg/L) | | | | |
| 1-2-B-CF | Classroom faucet in Classroom B | 2.9 | <1.0 | |