



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Enid Public Schools
 School: Hayes Elementary School
 Sampling Date: 6/8/2022
 Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Enid Public Schools - Hayes Elementary School on June 8, 2022. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Elkay water cooler with bottle filler to right of Room 113	<1.0	<1.0	N/A
1-1-HALL-WC2	Elkay bottle filler to right of Room 113	<1.0	<1.0	N/A
1-1-HALL-WC3	Elkay water cooler with bottle filler near Room 103	<1.0	<1.0	N/A
1-1-HALL-WC4	Elkay bottle filler near Room 103	<1.0	<1.0	N/A
1-1-TL-KF	Kitchen faucet in teachers' lounge; Smaller faucet	<1.0	<1.0	N/A
1-1-HALL-WC5	Elkay water cooler with bottle filler to left of Room 124	<1.0	<1.0	N/A
1-1-HALL-WC6	Elkay bottle filler to left of Room 124	<1.0	<1.0	N/A