



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Forest Grove Public SchoolsSchool: Forest Grove SchoolsSampling Date: 9/3/2021Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Forest Grove Public Schools on September 3, 2021. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Fourteen (14) samples had no detectable level of lead.
- Ten (10) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Two (2) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-ADMIN-KF	Administration building; Kitchen faucet in Administration building	<1.0	<1.0	N/A
2-1-CAFÉ-CF	Cafeteria building; Handwashing sink on back wall of cafeteria	<1.0	<1.0	N/A
2-1-CAFÉ-IM	Cafeteria building; Manitowoc ice machine in cafeteria	<1.0	<1.0	N/A
6-1-3YR-CF1	Elementary School; Classroom faucet in 3-year-olds room; left side	<1.0	<1.0	N/A
6-1-3YR-CF2	Elementary School; Classroom faucet in 3-year-olds room; right side	<1.0	<1.0	N/A
7-1-ED-KF	Special Ed building; Kitchen faucet at entrance to Special Ed building	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
6-1-HALL-WC	Elementary School; Elkay water cooler near boys' restroom	1.1	1.1	
2-1-CAFÉ-KF	Cafeteria building; Kitchen faucet in cafeteria	1.8	<1.0	
5-1-MS-WC	Middle School; Elkay water cooler in middle school hallway	3.1	3.7	

Sample ID	Comments	First Draw ( $\mu\text{g/L}$ )	Flush ( $\mu\text{g/L}$ )	Remedial Action
		Initial Sampling		
4-1-HALL-WC	Locker Room building; Elkay water cooler in hallway to locker rooms	4.5	5.7	
2-1-CAFÉ-WC	Cafeteria building; Elkay water cooler at entrance to cafeteria	6.8	2.6	
<b>High Detection (<math>\geq 15.0 \mu\text{g/L}</math>)</b>				
5-1-GYM-KF	Middle School; Kitchen faucet in concessions stand in gym	16.1	2.8	
3-1-B&GC-KF	Boys and Girls Club building; Kitchen faucet in storage room of boys and girls club	16.8	<1.0	