



OKLAHOMA DRINKING WATER
LEAD TESTING
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Gypsy Public Schools
 School: Gypsy Public Schools
 Sampling Date: 1/6/2023
 Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Gypsy Public Schools on January 6, 2023. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Nine (9) samples had no detectable level of lead.
- Eleven (11) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Six (6) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-CLOSET-IM	Main building; ice machine in hot water heater closet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-GIRLS-BF2	Main building; Bathroom faucet in girls' restroom; right side	2.1	<1.0	
1-1-BOYS-BF2	Main building; Bathroom faucet in boys' restroom; right side	4.3	<1.0	
2-1-EDC-BF3	EDC building; Bathroom faucet in teachers' bathroom in Room 2	5.6	<1.0	
1-1-BOYS-BF1	Main building; Bathroom faucet in boys' restroom; left side	6.4	<1.0	
1-1-GIRLS-BF1	Main building; Bathroom faucet in girls' restroom; left side	10.1	<1.0	
2-1-EDC-BF2	EDC building; Bathroom faucet in students' bathroom in Room 1	13.4	<1.0	
1-1-CAFÉ-KF	Main building; Kitchen faucet in cafeteria kitchen	14.1	1.4	
High Detection (≥15.0 µg/L)				
2-1-EDC-CF1	EDC building; Classroom faucet in Room 1	18.5	1.3	
2-1-EDC-BF4	EDC building; Bathroom faucet in students' bathroom in Room 2	34.5	<1.0	

Sample ID	Comments	First Draw ($\mu\text{g/L}$)	Flush ($\mu\text{g/L}$)	Remedial Action
		Initial Sampling		
2-1-EDC-BF1	EDC building; Bathroom faucet in teachers' bathroom in Room 1	36.5	1.3	
1-1-TL-CF	Main building; Classroom faucet in teachers' lounge	40.2	291	
2-1-EDC-CF2	EDC building; Classroom faucet in Room 2	913	3.9	