



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Kids' Ranch Child Care LLC  
 School: Kids Ranch Childcare  
 Sampling Date: 9/21/2021  
 Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Kids' Ranch Child Care LLC - Kids Ranch Childcare on September 21, 2021. Overall, forty-eight (48) outlets were tested resulting in a total of ninety-six (96) samples being sent to the lab.

- Ninety-one (91) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-RM1-CF1	Main building; Classroom faucet in Room 1; left side (10-month-olds)	<1.0	<1.0	N/A
1-RM1-CF2	Main building; Classroom faucet in Room 1; right side (10-month-olds)	<1.0	<1.0	N/A
1-RM2-CF1	Main building; Classroom faucet in Room 2; small white sink on right side (10–18-month-olds)	<1.0	<1.0	N/A
1-RM2-CF3	Main building; Classroom faucet in Room 2; big sink on left side (10–18-month-olds)	<1.0	<1.0	N/A
1-RM3-CF1	Main building; Classroom faucet in Room 3; small sink on right side (6+ year-olds)	<1.0	<1.0	N/A
1-RM3-CF2	Main building; Classroom faucet in Room 3; small sink on left side (6+ year-olds)	<1.0	<1.0	N/A
1-RM3-CF3	Main building; Classroom faucet in Room 3; Sink near changing table	<1.0	<1.0	N/A
1-RM3-CF4	Main building; Classroom faucet in Room 3; large sink near dishwasher	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-RM4-CF1	Main building; Classroom faucet in Room 4; small sink on right side (18 months-2 years)	<1.0	<1.0	N/A
1-RM4-CF2	Main building; Classroom faucet in Room 4; small sink in middle (18 months-2 years)	<1.0	<1.0	N/A
1-RM4-CF3	Main building; Classroom faucet in Room 4; small sink on left side (18 months-2 years)	<1.0	<1.0	N/A
1-RM5-CF1	Main building; Classroom faucet in Room 5; small sink on right side (2-year-olds)	<1.0	<1.0	N/A
1-RM5-CF2	Main building; Classroom faucet in Room 5; small sink in middle (2-year-olds)	<1.0	<1.0	N/A
1-RM5-CF3	Main building; Classroom faucet in Room 5; large sink on left side (2-year-olds)	<1.0	<1.0	N/A
1-RM6-CF1	Main building; Classroom faucet in Room 6; small sink on right side (2-year-olds)	<1.0	<1.0	N/A
1-RM6-CF2	Main building; Classroom faucet in Room 6; small sink in middle (2-year-olds)	<1.0	<1.0	N/A
2-3YRS-CF1	Second building; Classroom faucet in 3yo classroom; left side	<1.0	<1.0	N/A
2-3YRS-CF3	Second building; Classroom faucet in 3yo classroom; right side	<1.0	<1.0	N/A
2-KIT-KF	Second building; Kitchen faucet in kitchen; left side without sprayer	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-RM2-CF2	Main building; Classroom faucet in Room 2; small white sink in middle (10-18-month-olds)	1.3	<1.0	
1-RM6-CF3	Main building; Classroom faucet in Room 6; small sink on left side (2-year-olds)	1.5	<1.0	
1-RM3-CF5	Main building; Classroom faucet in Room 3 restroom; large sink near door	1.9	<1.0	
2-3YRS-CF2	Second building; Classroom faucet in 3yo classroom; middle sink	2.1	<1.0	
2-LAUNDRY-CF	Second building; Classroom faucet in laundry room; large sink	4.4	<1.0	