



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: C.A.R.D. HeadStartsSchool: New Orleans HeadStartSampling Date: 8/2/2023Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at C.A.R.D. HeadStart - Broken Arrow, New Orleans location on August 2, 2023. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Twenty-six (26) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-5-KF	Kitchen faucet in back of Room 5	<1.0	<1.0	N/A
1-1-5-CF	Classroom faucet in Room 5	<1.0	<1.0	N/A
1-1-4-KF	Kitchen faucet in back of Room 4	<1.0	<1.0	N/A
1-1-4-CF	Classroom faucet in Room 4	<1.0	<1.0	N/A
1-1-KIT-KF	Kitchen faucet in kitchen sink	<1.0	<1.0	N/A
1-1-KIT-IM	Manitowoc ice machine in kitchen	<1.0	<1.0	N/A
1-1-HALL-WC	Elkay water cooler in front hall; left of front desk	<1.0	<1.0	N/A
1-1-3-KF	Kitchen faucet in back of Room 3	<1.0	<1.0	N/A
1-1-3-CF	Classroom faucet in Room 3	<1.0	<1.0	N/A
1-1-2-KF	Kitchen faucet in back of Room 2	<1.0	<1.0	N/A
1-1-2-CF	Classroom faucet in Room 2	<1.0	<1.0	N/A
1-1-1-KF	Kitchen faucet in back of Room 1	<1.0	<1.0	N/A
1-1-1-CF	Classroom faucet in Room 1	<1.0	<1.0	N/A