



RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Sunbeam Family Services - Edwards Early Education Center and HeadStart on January 12, 2024. Overall, seventy-six (76) outlets were tested resulting in a total of one hundred fifty-two (152) samples being sent to the lab.

- Eighty-nine (89) samples had no detectable level of lead.
- Fifty-three (53) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Ten (10) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-C109-BF	Bathroom faucet in Room C109 bathroom	<1.0	<1.0	N/A
1-1-C109-CF3	Short handwash faucet in Room C109	<1.0	<1.0	N/A
1-1-C105-CF3	Short handwash faucet in Room C105	<1.0	<1.0	N/A
1-1-C107-BF	Bathroom faucet in Room C107 bathroom	<1.0	<1.0	N/A
1-1-C107-CF3	Short handwash faucet in Room C107	<1.0	<1.0	N/A
1-1-C102-CF3	Short handwash faucet in Room C102	<1.0	<1.0	N/A
1-1-A103-IM1	Ice machine in Room A103	<1.0	<1.0	N/A
1-1-A103-IM2	Drinking water dispenser attached to ice machine in Room A103	<1.0	<1.0	N/A
1-1-A104-CF1	Left tall handwash faucet in Room A104	<1.0	<1.0	N/A
1-1-A104-CF2	Right tall handwash faucet in Room A104	<1.0	<1.0	N/A
1-1-A104-CF3	Short handwash faucet in Room A104	<1.0	<1.0	N/A
1-1-A107-CF1	Left tall handwash faucet in Room A107	<1.0	<1.0	N/A
1-1-A107-CF2	Right tall handwash faucet in Room A107	<1.0	<1.0	N/A

Sample ID	Description	First Draw ($\mu\text{g/L}$)	Flush ($\mu\text{g/L}$)	Remedial Action
		Initial Sampling		
1-1-A107-CF3	Short handwash faucet in Room A107	<1.0	<1.0	N/A
1-1-A111-CF1	Left tall handwash faucet in Room A111	<1.0	<1.0	N/A
1-1-A111-CF2	Right tall handwash faucet in Room A111	<1.0	<1.0	N/A
1-1-A112-IM	Ice machine in Room A112	<1.0	<1.0	N/A
1-1-HALL-WC2	Elkay water cooler; between Rooms A111 and A113	<1.0	<1.0	N/A
1-1-A113-CF2	Right tall handwash faucet in Room A113	<1.0	<1.0	N/A
1-1-A113-CF3	Short handwash faucet in Room A113	<1.0	<1.0	N/A
1-1-A114-CF1	Left tall handwash faucet in Room A114	<1.0	<1.0	N/A
1-1-A114-CF2	Right tall handwash faucet in Room A114	<1.0	<1.0	N/A
1-1-A114-CF3	Short handwash faucet in Room A114	<1.0	<1.0	N/A
1-1-C115-CF3	Short handwash faucet in Room C115	<1.0	<1.0	N/A
2-1-HALL-WC1	Add-on building; Elkay water cooler; left side; At hallway intersection	<1.0	<1.0	N/A
2-1-HALL-WC2	Add-on building; Elkay water cooler; right side; At hallway intersection,	<1.0	<1.0	N/A
3-1-HALL-WC1	Elkay water cooler; left side; Next to bathroom in gym	<1.0	<1.0	N/A
3-1-HALL-WC2	Elkay water cooler; right side; Next to bathroom in gym	<1.0	<1.0	N/A
3-1-G103-KF	Kitchen handwash faucet in Room G103	<1.0	<1.0	N/A
3-1-G103-IM1	Ice machine in Room G103	<1.0	<1.0	N/A
3-1-G103-IM2	Drinking water dispenser attached to ice machine in Room G103	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 $\mu\text{g/L}$)				
1-1-C108-CF3	Short handwash faucet in Room C108	<1.0	1.1	
1-1-C102-BF	Bathroom faucet in Room C102 bathroom	<1.0	1.2	
1-1-A111-CF3	Short handwash faucet in Room A111	<1.0	1.9	
1-1-A113-CF1	Left tall handwash faucet in Room A113	1.0	<1.0	
2-1-E107-CF1	Add-on Building; Handwash faucet in Room E107	1.0	<1.0	

Sample ID	Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-A112-KF	Large dishwashing faucet in Room A112	1.1	<1.0	
1-1-A107-BF	Bathroom faucet in Room A107 bathroom	1.5	<1.0	
1-1-HALL-WC1	Elkay water cooler; Between Rooms C105 and C108	1.5	1.8	
1-1-A104-BF	Bathroom faucet in Room A104 bathroom	1.6	<1.0	
1-1-A114-BF	Bathroom faucet in Room A114 bathroom	1.6	<1.0	
2-1-E107-CF2	Add-on building; Drinking water bubbler in Room E107	1.6	<1.0	
1-1-A115-KF	Handwash faucet in Room A115	1.7	<1.0	
1-1-A113-BF	Bathroom faucet in Room A113 bathroom	1.8	<1.0	
1-1-A111-BF	Bathroom faucet in Room A111 bathroom	1.9	<1.0	
2-1-E104-CF1	Add-on building; Handwash faucet in Room E104	1.9	<1.0	
1-1-C108-CF2	Right tall handwash faucet in Room C108	2.2	<1.0	
1-1-C112-CF3	Short handwash faucet in Room C112	2.2	<1.0	
1-1-C108-CF1	Left tall handwash faucet in Room C108	2.3	<1.0	
1-1-C115-BF	Bathroom faucet in Room C115 bathroom	2.5	<1.0	
2-1-E103-CF1	Add-on building; Handwash faucet in Room E103	2.7	<1.0	
2-1-E105-CF1	Add-on building; Handwash faucet in Room E105	2.9	<1.0	
2-1-C121-42I-CF	Add-on building; Backroom handwash faucet in Room C121/42I	3.1	<1.0	
1-1-C108-BF	Bathroom faucet in Room C108 bathroom	3.1	2.9	
2-1-E105-CF2	Add-on building; Drinking water bubbler in Room E105	3.2	<1.0	
2-1-E106-CF1	Add-on building; Handwash faucet in Room E106	3.2	<1.0	
2-1-E102-CF1	Add-on building; Handwash faucet in Room E102	4.2	<1.0	
2-1-E102-CF2	Add-on building; Drinking water bubbler in Room E102	4.2	<1.0	
1-1-C115-CF1	Left tall handwash faucet in Room C115	4.5	<1.0	
1-1-C103-KF	Kitchen handwash faucet in Room C103	5.4	1.3	
1-1-C105-CF1	Left tall handwash faucet in Room C105	5.4	1.8	

Sample ID	Description	First Draw ($\mu\text{g/L}$)	Flush ($\mu\text{g/L}$)	Remedial Action
		Initial Sampling		
1-1-A103-KF	Kitchen handwash faucet in Room A103	5.9	1.6	
1-1-C112-CF2	Right tall handwash faucet in Room C112	6.9	3.0	
1-1-C109-CF1	Left tall handwash faucet in Room C109	8.0	4.7	
1-1-C115-CF2	Right tall handwash faucet in Room C115	9.8	<1.0	
2-1-E103-CF2	Add-on building; Drinking water bubbler in Room E103	11.0	<1.0	
2-1-E104-CF2	Add-on building; Drinking water bubbler in Room E104	11.7	<1.0	
High Detection ($\geq 15.0 \mu\text{g/L}$)				
2-1-E106-CF2	Add-on building; Drinking water bubbler in Room E106	16.2	<1.0	
1-1-C105-BF	Bathroom faucet in Room C105 bathroom	17.0	1.1	
1-1-C105-CF2	Right tall handwash faucet in Room C105	18.9	2.5	
1-1-C102-CF1	Left tall handwash faucet in Room C102	20.0	4.3	
1-1-C109-CF2	Right tall handwash faucet in Room C109	21.1	1.8	
1-1-C112-CF1	Left tall handwash faucet in Room C112	32.6	5.2	
1-1-C102-CF2	Right tall handwash faucet in Room C102	42.0	6.9	
1-1-C107-CF1	Left tall handwash faucet in Room C107	46.9	6.9	
1-1-C107-CF2	Right tall handwash faucet in Room C107	53.9	7.1	
1-1-C112-BF	Bathroom faucet in Room C112 bathroom	57.6	3.9	