



OKLAHOMA DRINKING WATER  
**LEAD TESTING**  
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

School: Timberlake Elementary  
 District: Timberlake Public Schools  
 Sampling Date: 10/13/2022  
 Status: Complete

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Timberlake Elementary School on October 13, 2022. Overall, twelve (12) outlets were tested resulting in a total of twenty-four (24) samples being sent to the lab.

- Twenty-four (24) samples had no detectable level of lead.
- Zero (0) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-KIT-KF1	Kitchen faucet on handwashing sink in kitchen; used for food prep	< 1.0	< 1.0	N/A
1-1-KIT-KF2	Kitchen faucet in three-compartment sink	< 1.0	< 1.0	N/A
1-1-KIT-IM	Manitowoc ice machine outside of kitchen	< 1.0	< 1.0	N/A
1-1-HALL-WC1	Elkay water cooler; left side; between restrooms outside cafeteria	< 1.0	< 1.0	N/A
1-1-HALL-WC2	Elkay water cooler; right side; between restrooms outside cafeteria	< 1.0	< 1.0	N/A
1-1-HALL-WC3	Elkay water cooler with bottle filler; Past restrooms near front of school	< 1.0	< 1.0	N/A
1-1-HALL-WC4	Elkay bottle filler; Past restrooms near front of school	< 1.0	< 1.0	N/A
1-1-HALL-WC5	Elkay water cooler; by gym with bottle filler; outside front office	< 1.0	< 1.0	N/A
1-1-HALL-WC6	Elkay Bottle Filler by gym; outside front office	< 1.0	< 1.0	N/A
1-1-HALL-WC7	Elkay Water Cooler, older part of the school, between restrooms; west side of school	< 1.0	< 1.0	N/A

Sample ID	Description	First Draw ( $\mu\text{g/L}$ )	Flush ( $\mu\text{g/L}$ )	Remedial Action
		Initial Sampling		
1-1-HALL-WC8	Bottle filler; older part of the school, between restrooms; west side of school	< 1.0	< 1.0	N/A
1-1-CON-KF	Kitchen faucet in concessions stand by football field	< 1.0	< 1.0	N/A