



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Tushka Public SchoolsSchool: Tushka Public SchoolsSampling Date: 9/16/2021Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Tushka Public Schools on September 16, 2021. Overall, twenty-five (25) outlets were tested resulting in a total of fifty (50) samples being sent to the lab.

- Forty-four (44) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-KIT-KF	Kitchen faucet in school kitchen; on back wall near storage room	<1.0	<1.0	N/A
1-KIT-IM	Manitowoc ice machine in school kitchen	<1.0	<1.0	N/A
1-CAFÉ-KF	Kitchen faucet in eating area of cafeteria	<1.0	<1.0	N/A
1-CAFÉ-IM	Ice machine in eating area of cafeteria	<1.0	<1.0	N/A
1-MS-WC1	Halsey Taylor water cooler with bottle filler in middle school hallway; left side	<1.0	<1.0	N/A
1-MS-WC2	Halsey Taylor bottle filler in middle school hallway; left side	<1.0	<1.0	N/A
1-MS-WC3	Halsey Taylor water cooler in middle school hallway; right side	<1.0	<1.0	N/A
1-MSTL-KF	Kitchen faucet in middle school teachers' lounge	<1.0	<1.0	N/A
1-HALL-WC	Halsey Taylor water cooler in hall outside of gym; near storage room	<1.0	<1.0	N/A
1-ELEM-WC1	Halsey Taylor water cooler in elementary school hallway; right side	<1.0	<1.0	N/A

Sample ID	Comments	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-ELEM-WC2	Halsey Taylor water cooler with bottle filler in elementary school hallway; left side	<1.0	<1.0	N/A
1-ELEM-WC3	Halsey Taylor bottle filler in elementary school hallway; left side	<1.0	<1.0	N/A
1-HSTL-KF	Kitchen faucet in high school teachers' lounge	<1.0	<1.0	N/A
1-HS-WC1	Elkay water cooler with bottle filler in high school hallway; near girls' restroom	<1.0	<1.0	N/A
1-HS-WC2	Elkay bottle filler in high school hallway; near girls' restroom	<1.0	<1.0	N/A
1-HS-WC3	Elkay water cooler with bottle filler in high school hallway; near boys' restroom	<1.0	<1.0	N/A
1-HS-WC4	Elkay bottle filler in high school hallway; near boys' restroom	<1.0	<1.0	N/A
1-FS-KF1	Kitchen faucet in high school family science room; left side	<1.0	<1.0	N/A
1-FS-KF2	Kitchen faucet in high school family science room; right side	<1.0	<1.0	N/A
2-BASE-KF1	Kitchen faucet in baseball field concessions stand; left side	<1.0	<1.0	N/A
2-BASE-IM	Koolaire ice machine in baseball field concessions stand	<1.0	<1.0	N/A
2-BASE-KF2	Kitchen faucet in baseball field concessions stand; right side	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
3-GYM-KF	Kitchen faucet in concessions stand of old gym	11.0	2.4	Flush
3-GYM-WC1	Elkay water cooler near visitors' section of old gym; right side	1.2	1.3	Flush
3-GYM-WC2	Elkay water cooler near home section of old gym; left side	1.1	1.2	Flush